



City of Attleboro, Massachusetts  
WATER DEPARTMENT  
1296 West Street  
Attleboro, Massachusetts 02703  
Phone 774-203-1850 ♦ Fax 508-223-2271

## **Water Department Specifications:**

All line gates and hydrants are open right.  
All curb stops open left.

### Water Mains & Services:

- Ductile iron pipe, C-52 150 psi for all water mains.
- Copper pipe, type K, for all water services box to main.
- Polyplastic pipe allowed on private property with Department approval only.
- DI piping, push on and mechanical joints. Mega lug for bends of 45 and 90 degrees. This is at the discretion of the Department.

### Service Valves:

- Flared and compression.
- Mueller and Ford products, or equal with Department approval.
- Curb stops, corporations, couplings, and unions.
- Rodded boxes on all new installations.

### Hydrants:

- Mueller Centurion A-423 or American Darling B-62B.
- Thrust blocks required on all installations.

### Water Meters:

- Water meters must register in cubic feet with 2-wire remote.
- Sizes 5/8" – 2" positive displacement.
- Compound meters required for larger services.
- <https://www.cityofattleboro.us/DocumentCenter/View/2536/New-Water-Service-Policy-PDF>

### Street Valves:

- Mueller and Ford products, or equal with Department approval.
- Butterfly valves.
- Resilient seated valves.