

**ADDENDUM NO. 2**

City of Attleboro  
77 Park Street  
Attleboro, MA 02703

Date Issued: August 11, 2022

TO: ALL PLAN HOLDERS OF RECORD

RE: CITY OF ATTLEBORO, MASSACHUSETTS

REQUEST FOR QUALIFICATIONS: **Engineering, Permitting Assistance, Design, Bidding Assistance, and Resident Services for the Removal and Replacement of Approximately 10,800 Linear Feet of Water Main on Lindsey Street**

Proposals due: August 29, 2022 @ 11:00 a.m.

ADDENDUM NO. 2

This Addendum shall be part of the Request For Qualifications for **Engineering, Permitting Assistance, Design, Bidding Assistance, and Resident Services for the Removal and Replacement of Approximately 10,800 Linear Feet of Water Main on Lindsey Street**. This Addendum form is part of the RFP and modifies the original document. Proposers shall acknowledge receipt of the addendum by signing this addendum at the bottom and including it with the proposal. Failure to do so may subject the proposer to disqualification.

Questions:

1. Describe the extents of the 10,800 feet water main replacement. (From what street to what street): *Pleasant to just past Jacap*
2. Are record drawings available to review: *We have GIS and wall maps, but no original as builts*
3. What is the material of the existing 8" main: *lied cast iron*
4. Approximately how many house connections exist on the main: *approximately 150*
5. Are you proposing a same trench replacement with temporary by-pass piping, or adjacent trench and abandoning the existing pipe in place: *same trench with a bypass*
6. Will the water main be crossing under the Northeast Corridor Rail line or is it hung on the bridge: *hung*
7. If so, is there a sleeve in the crossing: *12 DI sleeved. There is a valve at either side of the bridge.*
8. What side of the road is the existing water main, northbound or southbound: *predominantly northbound*
9. What other buried utilities exist in Lyndsey Street, there appears to be gas in the southern lanes: *There is no sewer. The gas company would need to be contacted to determine if there is an existing gas line.*
10. Any consideration on lining rather than replacing the main: *No. The existing main has a long history of common breaks*

**RECEIPT OF ADDENDUM**

COMPANY NAME: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

**This addendum form must be submitted with the bid.**

(END ADDENDUM NO.2)